



**Ingham Hill**  
**Septic System Improvement Program**  
**Town of Old Saybrook, CT**



Date: April, 2005

Legend		# OF LOTS	% OF LOTS
<span style="color: red;">■</span>	AT System and Compact Leaching System Required (Leaching Area Available < 1/2 of PHC Requirement).....	0	0%
<span style="color: magenta;">■</span>	AT System Required Due to Leaching Area Available (1/2 of PHC Required < Leaching Area Available < 2/3 of PHC Requirement).....	0	0%
<span style="color: yellow;">■</span>	2/3 PHC Requirement < Leaching Area Available < PHC Requirement.....	0	0%
<span style="background-color: white; border: 1px solid black;">■</span>	Leaching Area Available > PHC Requirement.....	16	100%
<span style="color: cyan;">W</span>	AT System Required Due to Waterfront Lot.....	2	13%
<span style="background-color: white; border: 1px solid black; border-style: dashed;">■</span>	Drywell Removal & Replacement with New Leaching System.....	2	13%
<span style="background-color: white; border: 1px solid black; border-style: dotted;">■</span>	Undersized Septic Tanks.....	4	25%
<span style="background-color: green;">■</span>	Vacant Lots.....	1	
<span style="color: cyan;">—</span>	Wetlands		
PHC = Public Health Code			
		Total Number of Developed Lots: 16	